



LEGEND

- CONDUCTORS CONNECTED
- CONDUCTORS NOT CONNECTED
- CONDUCTOR INDICATING LOAD DIRECTION
- CURRENT TRANSFORMER

Only qualified electrical personnel should install this equipment.

- Before performing installation or maintenance, disconnect all sources of electric power.
- Use appropriate personal protective equipment (PPE) and follow safe electrical work practices.

- Installation Notes:**
- 1) Auditor is DIN-rail mounted and requires 35mm wide space.
 - 2) Current transformer installation –
For grid monitoring, K is towards grid, arrow is towards load.
For load monitoring, K is towards grid, arrow is towards load.
 - 3) Current transformers must be suitably secured in position.
 - 4) All wiring shall be tidy and secured in accordance with the wiring rules in your jurisdiction.
 - 5) An existing or new protective device can be used depending on the regulations in your jurisdiction.
 - 6) Follow the rules in your jurisdiction for the use of RCD protection.
 - 7) For more information, refer to the quick start guide and wattwatchers.com.au/support

Place current transformer connected to...	On cables connected to...
Terminals 1+ and 4+	A-Phase
Terminals 2+ and 5+	B-Phase
Terminals 3+ and 6+	C-Phase

Find diagrams for more configurations at wattwatchers.com.au/support

Issue	Description	Drawn	Approved	Date
1	Final	KS	JC	03/19



T 2 9 WATTWAT
A M T V A T T T T A W
I T A T M T A W T A W
A T A W A V W T T T W T
WATTWAT

Client Details

Drawn By: KS
Date: 03/19
Approved By: JC
Date: 03/19

Project title: CONNECTION DIAGRAMS

Drawing title: A6W MONITORING 3-PHASE MAINS + 1-PHASE LOAD CONNECTION DIAGRAM

Project Code: 20180153
Drawing No: WW018039
Status: FINAL
Revision: A
Scale: NTS