



LEGEND

- +— CONDUCTORS CONNECTED
- |- CONDUCTORS NOT CONNECTED
- ← CONDUCTOR INDICATING LOAD DIRECTION
- CURRENT TRANSFORMER

Only qualified electrical personnel should install this equipment.

- Before performing installation or maintenance, disconnect all sources of electric power.
- Use appropriate personal protective equipment (PPE) and follow safe electrical work practices.

Find diagrams for more configurations at wattwatchers.com.au/support

- Installation Notes:**
- 1) Auditor is DIN-rail mounted and requires 35mm wide space.
 - 2) Current transformer installation –
For grid monitoring, K is towards grid, arrow is towards load.
For load monitoring, K is towards grid, arrow is towards load.
 - 3) Current transformers must be suitably secured in position.
 - 4) All wiring shall be tidy and secured in accordance with the wiring rules in your jurisdiction.
 - 5) An existing or new protective device can be used depending on the regulations in your jurisdiction.
 - 6) Follow the rules in your jurisdiction for the use of RCD protection.
 - 7) Wattwatchers recommends the placement of monitoring CT's on the circuits being switched, but this is not mandatory.
 - 8) For more information, refer to the quick start guide and wattwatchers.com.au/support

Place current transformer connected to...	On cables connected to...
Terminals 1+ and 4+	A-Phase
Terminals 2+ and 5+	B-Phase
Terminals 3+ and 6+	C-Phase

Issue	Description	Drawn	Approved	Date
1	Final	KS	JC	03/19



T 2 9 WATTWAT
A M A T V A T T T T A W
I T A T M T A W T T A W
A T A W M V W T T W T T
WATTWAT

Client Details

Drawn By
KS
Approved By
JC
Date
03/19
Date
03/19

Project title
CONNECTION DIAGRAMS

Drawing title
A6W+3SW
MONITORING 3-PHASE MAINS
+ 1-PHASE LOAD MONITOR+SWITCH

Project Code
20180153
Drawing No
WW018040
Status
FINAL
Revision
A
Scale
NTS